

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1062:121 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060 Fax (585) 421-4263

DESIGN: Model DS432 Reversing Relay Module. The unit is designed to convert an initiating circuit from a control panel to a reversing smoke power detection circuit. Unit is intended for installation within the control unit's enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessory for use with separately listed compatible fire alarm control units.

XLF: 7300-0801:198

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager